

SECTION 7, T24N, R2W, HIGGINS TOWNSHIP, ROSCOMMON COUNTY

PROPOSED 2011 VILLAGE OF ROSCOMMON M-18 DEVELOPMENT WATER MAIN PROJECT

SECTION 7, T24N, R2W, HIGGINS TOWNSHIP, ROSCOMMON COUNTY

PLAN SHEET INDEX



- C1 TITLE SHEET
- C2 LAYOUT, LEGEND AND GENERAL NOTES
- C3 WATER MAIN THRUST BLOCK DETAILS
- C4 WATER DETAILS

A.S.T.M. - A.W.W.A SPEC LIST

WHERE THE FOLLOWING ITEMS ARE CALLED FOR ON THE PLANS, THEY ARE TO BE CONSTRUCTED ACCORDING TO THE STANDARD GIVEN BELOW THAT IS OPPOSITE FROM EACH ITEM, UNLESS OTHERWISE INDICATED BY THE ENGINEER.

WATER MAIN PIPE	C905-97
VALVES	C509-01, C504-00
PRESSURE TESTING	C806-84
HYDRANTS	C802-84

Vicinity Map



TRAFFIC CONTROL AND PERMANENT SIGNING SHALL BE MAINTAINED IN ACCORDANCE WITH SECTIONS 103.06, 103.06 AND 512 OF THE 2003 MICHIGAN DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS FOR CONSTRUCTION, THE 2005 MICHIGAN MANUAL OF UNIFORM TRAFFIC CONTROL DEVICES AS AMENDED AND INCLUDING ANY SUPPLEMENTAL SPECIFICATIONS, AND AS HEREIN SPECIFIED WITHIN THE PLANS.

THE IMPROVEMENTS COVERED BY THESE PLANS ARE IN ACCORDANCE WITH THE MICHIGAN SAFE DRINKING WATER ACT AND THE RULES PROMULGATED UNDER ACT 506, AS AMENDED.

IT IS UNDERSTOOD THAT THE CONTRACTOR SHALL PERFORM ALL WORK UNDER THIS CONTRACT IN ACCORDANCE WITH ALL APPLICABLE PROVISIONS, POLICIES, RULES AND STANDARDS OF THE MICHIGAN OCCUPATIONAL SAFETY AND HEALTH ACT (PROHIBITING ACT 154 OF THE PUBLIC ACTS OF 1974 AND AS AMENDED).

EXCEPT WHERE OTHERWISE INDICATED ON THE PLANS OR IN THE PROPOSAL AND SUPPLEMENTAL SPECIFICATIONS CONTAINED THEREIN, ALL MATERIALS AND WORKMANSHIP SHALL BE IN ACCORDANCE WITH THE APPLICABLE SECTIONS OF THE MICHIGAN DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS FOR CONSTRUCTION, 2003 EDITION, AND THE CURRENT SUPPLEMENTAL SPECIFICATIONS.

NOTE: CALL MICHIGAN (800)462-7131
WORKING DAYS PRIOR TO ANY EXCAVATION
FOR UNDERGROUND UTILITY INFORMATION

Plan P 1420 P1 No. 50009
JWA, SMC/SL/A/A
3/24/11

150 FEET OF NEW 12" WATER MAIN, VALVES AND ONE HYDRANT IN THE VILLAGE OF ROSCOMMON, BEING IN THE SOUTHEAST 1/4 OF THE SOUTHEAST 1/4 OF SECTION 7, T24N, R2W, HIGGINS TOWNSHIP, ROSCOMMON COUNTY.

VILLAGE OF ROSCOMMON

Jesse Carlson, Village President
Tim Sadowski, Village Manager

PREPARED UNDER SUPERVISION OF

Prepared For
Village of Roscommon
214 S. Main Street, P.O. Box 236
Roscommon, Michigan 49853

MICHIGAN REGISTERED PROFESSIONAL ENGINEER

VILLAGE OF ROSCOMMON

M-18 DEVELOPMENT WATER MAIN PROJECT

DATE: FEBRUARY 1, 2011
DRAWN BY: JWA
CHECKED BY: SMC
DESIGNED BY: JWA
TITLE SHEET

JWA & SMC/SL/A/A, Inc.
Professional Engineers
3157 W. W. N. Park E
West Branch, Michigan 48891
Ph: (504) 345-1100
Fax: (504) 345-1100
www.jwaandsmc.com

2011 M-18 DEVELOPMENT WATER MAIN PROJECT

TITLE SHEET

C-1

